



**2016 Consumer Confidence Report  
Annual Drinking Water Quality Report  
Town of Stedman  
PWS ID# 03-26-030**

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is a review of last year's water quality. Included are details about the source of your drinking water, what it contains, and how it compares to standards set by regulatory agencies. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water and to providing you with this information, because informed customers are our best allies. **If you have any questions about this report or concerning your water, please contact Rebecca Johnson at 910-323-1892. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 1<sup>st</sup> Thursday of each month at 7:00PM at the Stedman Town Hall.**

### **WHAT EPA WANTS YOU TO KNOW**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Town of Stedman is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include **microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; **inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; **pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; **organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; and **radioactive contaminants**, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

## WHEN YOU TURN YOUR TAP, CONSIDER THE SOURCE

The water that is used by this system is surface water that is treated and purchased from the Public Works Commission of Fayetteville. Please see the City of Fayetteville's 2016 Annual Drinking Water Quality Report at <http://www.faypwc.com/water-quality-report/> to find the source of their drinking water, as well as more in depth lab testing results of tests performed on your drinking water.

## SOURCE WATER ASSESSMENT PROGRAM (SWAP) RESULTS

The North Carolina Department of Environment and Natural Resources (DENR), Public Water Supply (PWS) Section, Source Water Assessment Program (SWAP) conducted assessments for all drinking water sources across North Carolina. The purpose of the assessments was to determine the susceptibility of each drinking water source (well or surface water intake) to Potential Contaminant Sources (PCSs). The results of the assessment are available in SWAP Assessment Reports that include maps, background information and a relative susceptibility rating of Higher, Moderate or Lower.

The relative susceptibility rating of each source for Town of Stedman was determined by combining the contaminant rating (number and location of PCSs within the assessment area) and the inherent vulnerability rating (i.e., characteristics or existing conditions of the well or watershed and its delineated assessment area). The assessment findings are summarized in the table below:

Susceptibility of Sources to Potential Contaminant Sources (PCSs)

Source Name*	Susceptibility Rating	SWAP Report Date
Glenville Lake	Higher	July 2015
Cape Fear River	Higher	July 2015

\*From Public Works Commission (PWC) Public Water ID 0326010

The complete SWAP Assessment report for Town of Stedman and PWC may be viewed on the Web at [www.ncwater.org/pws/swap](http://www.ncwater.org/pws/swap). Note that because SWAP results and reports are periodically updated by the PWC Section, the results available on this web site may differ from the results that were available at the time this CCR was prepared. If you are unable to access your SWAP report on the web, you may mail a written request for a printed copy to: Source Water Assessment Program—Report Request, 1634 Mail Service Center, Raleigh, NC 27699-1634, or email requests to [swap@ncdenr.gov](mailto:swap@ncdenr.gov). Please indicate your system name, number, and provide your name, mailing address and phone number. If you have any questions about the SWAP report please contact the Source Water Assessment staff by phone at 919-707-9098.

It is important to understand that a susceptibility rating of "higher" does not imply poor water quality, only the system's potential to become contaminated by PCSs in the assessment area.

## HELP PROTECT YOUR SOURCE WATER

Protection of drinking water is everyone's responsibility. You can protect your community's drinking water source (s) in several ways: (examples: dispose of chemicals properly, take used motor oil to a recycling center, volunteer in your community to participate in group efforts to protect your source, etc...)

## WATER QUALITY DATA TABLES OF DETECTED CONTAMINANTS

We routinely monitor for **over 150 contaminants in your drinking water according to Federal and State laws. The table below lists all the drinking water contaminants that we detected** in the last round of sampling for the particular contaminant group. The presence of contaminants does not necessarily indicate that water poses a health risk. **Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2016.** The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

### **Important Drinking Water Definitions:**

**Not-Applicable (N/A)** - Information not applicable/not required for that particular water system or for that particular rule.

**Non-Detects (ND)** - Laboratory analysis indicates that the contaminant is not present at the level of detection set for the particular methodology used.

**Parts per million (ppm) or Milligram per liter (mg/L)** - One part per million corresponds to the one minute in two years or single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter (ug/L)** - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Million Fibers per Liter (MFL)** - Million fibers per liter is a measure of the presence of asbestos fibers that are no longer than 10 micrometers.

**Action Level (AL)** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Residual Disinfection Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfection Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Locational Running Annual Average (LRAA)** - The average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters under the Stage 2 Disinfectants and Disinfection Byproducts Rule.

**Maximum Contaminant Level (MCL)** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Extra Note: MCLs are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.**

## TABLES OF DETECTED CONTAMINANTS

**Microbiological Contaminants in the Distribution System**—For systems that collect *less than 40* samples per month

Contaminant (units)	MCL Violation Y/N	Your Water	MCL G	MCL	Likely Source of Contamination
Total Coliform Bacteria (presence or absence)	N	ND	0	One positive monthly sample	Naturally present in the environment
Fecal Coliform or E. coli (presence or absence)	N	ND	0	0 (Note: The MCL is exceeded if a routine sample and repeat sample are total coliform positive, and one is also fecal coliform or E. coli positive)	Human and animal fecal waste

\*If a system collection fewer than 40 samples per month has two positive samples in one month, the system has a MCL violation.

### Asbestos Contaminant

Contaminant (units)	Sample Date	MCL Violation Y?N	Your Water	Range High Low	MCLG	MCL	Likely Source of Contamination
Asbestos	2013	N	ND	BD	0	7MFL Millions per Liter	Asbestos Cement Pipe

### Lead and Copper Contaminants

Contaminant (units)	Sample Date	Your Water	# of sites found above the AL	MCLG	MCL	Likely Source of Contamination
Copper (ppm) (90th percentile)	2014	ND	0	1.3	AL = 1.3ppm	Corrosion of household plumbing systems, erosion of natural deposits; leaching from wood preservatives.
Lead (ppb) (90th percentile)	2014	ND	0	0	AL = 15ppb	Corrosion of household plumbing systems, erosion of natural deposits.

### Disinfectant Residuals

	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Sample 1	2.5	2.0	1.1	2.4	2.6	2.6	2.4	2.0	2.2	2.1	2.2	2.2
Sample 2	2.4	2.4	1.4	2.5	2.5	2.5	2.5	2.4	2.4	2.4	2.4	1.4
Monthly Avg	2.45	2.2	1.25	2.45	2.55	2.55	2.45	2.2	2.3	2.25	2.3	1.8
RAA*	1.96			2.51			2.31			2.11		

\*Reported RAA for quarters 1-3 are based on results from previous quarters not reported on this table.

### Disinfectant Residuals Summary

	Year Sampled	MRDL Violation Y/N	Your Water (highest RAA)	Range Low High	MRDLG	MRDL	Likely Source of Contamination
Chlorine (ppm)	March 2016	N	1.25	0.9 1.4	4	4.0	Water additive used to control microbes
Chloramines (ppm)	2016	N	2.51	1.4 2.6	4	4.0	Water additive used to control microbes

**Stage 2 Disinfection Byproduct Compliance**—Based upon Locational Running Annual Average (LRAA)

Disinfection ByProduct	Year Sampled	MCL Violation Y/N	Your Water (highest LRAA)	Range Low High	MCLG	MCL	Likely Source of Contamination
TTHM (ppb)							ByProduct of drinking water disinfection
Location BO2	2016	N	38	17 63	N/A	80	
Location BO1	2016	N	39	17 63	N/A	80	
HAA5 (ppb)							ByProduct of drinking water disinfection
Location BO2	2016	N	22	16 29	N/A	60	
Location BO1	2016	N	23	16 38	N/A	60	